

CERTIFICATE OF COMPLIANCE

Certificate Number 20150401-E183151
Report Reference E183151-20120814
Issue Date 2015-APRIL-01

Issued to: PROSOFT TECHNOLOGY INC
5201 Truxtun Ave 3
Bakersfield CA 93309-0421

**This is to certify that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN HAZARDOUS
LOCATIONS
See Addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. ANSI/ISA 12.12.01, 2013, Nonincendive Electrical
Equipment for Use in Class I and II, Division 2 and Class III,
Divisions 1 and 2 Hazardous (Classified) Locations.
CSA C22.2 No. 213-M1987 (R2013), Non-incendive Electrical
Equipment for Use in Class I, Division 2 Hazardous Locations
UL 508, Industrial Control Equipment
CSA C22.2 No. 142-M1987, Process Control Equipment

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150401-E183151
Report Reference E183151-20120814
Issue Date 2015-APRIL-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Programmable Logic Controllers PLX3x Gateway Series Modules where x can be 1 or 2, followed by any combination of EIP, MBTCP, MBS, MBS(4), MBS, MBS4, ASCII, ASCII4, DF1(4), DF1, 104, BACNET, EGD, DNPNET, DNPSNET, 61850S, 101, DNP, SIE and PND, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Programmable Logic Controllers PLX8x Gateway Series Modules where x can be 1 or 2, followed by EIP or MNET, Followed by 61850, Followed by Series A or B, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

