

Where Automation Connects.



PLX51-PBS

PROFIBUS DP Slave to EtherNet/IP™, Modbus® TCP/IP, or Modbus® Serial Gateway

Stand Alone Gateway

Your Feedback Please

We always want you to feel that you made the right decision to use our products. If you have suggestions, comments, compliments or complaints about our products, documentation, or support, please write or call us.

ProSoft Technology, Inc.

+1 (661) 716-5100

+1 (661) 716-5101 (Fax)

www.prosoft-technology.com ps.support@belden.com

PLX51-PBS Release Notes For Public Use.

October 16, 2025

ProSoft Technology®, is a registered copyright of ProSoft Technology, Inc. All other brand or product names are or may be trademarks of, and are used to identify products and services of, their respective owners.

Content Disclaimer

This documentation is not intended as a substitute for and is not to be used for determining suitability or reliability of these products for specific user applications. It is the duty of any such user or integrator to perform the appropriate and complete risk analysis, evaluation and testing of the products with respect to the relevant specific application or use thereof. Neither ProSoft Technology nor any of its affiliates or subsidiaries shall be responsible or liable for misuse of the information contained herein. Information in this document including illustrations, specifications and dimensions may contain technical inaccuracies or typographical errors. ProSoft Technology makes no warranty or representation as to its accuracy and assumes no liability for and reserves the right to correct such inaccuracies or errors at any time without notice. If you have any suggestions for improvements or amendments or have found errors in this publication, please notify us.

No part of this document may be reproduced in any form or by any means, electronic or mechanical, including photocopying, without express written permission of ProSoft Technology. All pertinent state, regional, and local safety regulations must be observed when installing and using this product. For reasons of safety and to help ensure compliance with documented system data, only the manufacturer should perform repairs to components. When devices are used for applications with technical safety requirements, the relevant instructions must be followed. Failure to use ProSoft Technology software or approved software with our hardware products may result in injury, harm, or improper operating results. Failure to observe this information can result in injury or equipment damage.

© 2025 ProSoft Technology. All Rights Reserved.

Contents

	Your I	2	
	Conte	ent Disclaimer	2
1	Start Here		4
	1.1	About the PLX51-PBS	4
	1.2	Release Enhancements	5
2	Support, Service & Warranty		6
	2.1	Contacting Technical Support	6
	2.2	Warranty Information	6

1 Start Here

This document highlights the new features, fixes, enhancements and known issues for the PLX51-PBS gateway.

1.1 About the PLX51-PBS

The PLX51-PBS gateway provides connectivity to EtherNet/IP™, Modbus® TCP/IP, or Modbus® Serial networks for PROFIBUS DP networks by operating as a PROFIBUS DP slave.

For easy integration to a Rockwell Automation Controller, the gateway and configuration software create dynamic AOI's based on the user configuration to add logical tag names to the PLC project file. Thus, reducing programming time.

For configuration of Modbus TCP/IP or Modbus Serial Networks, the module will automatically map PROFIBUS DP data points to registers on a Modbus network.

With advanced tools such as a built in PROFIBUS DP packet capture utility, PROFIBUS DP network commissioning time can be greatly reduced.

Dual Ethernet ports of the module can support either DLR (Device Level Ring) topology or can be used as an embedded switch for flexible installation options.

With support for up to 1536 bytes of Input and Output data, and up to 4 EtherNet/IP connections back to the processor, this module provides performance and data throughput for even the most demanding of PROFIBUS applications.

As a PROFIBUS DP slave device, the module can emulate from 1 to as many as 10 slave DP nodes, providing up to 1536 bytes of Input and Output Cyclic I/O data between EtherNet/IP devices and a PROFIBUS DP master. This eliminates the need for using DPV1 messaging when more than 244 bytes of data need to be exchanged between a PROFIBUS master and an EtherNet/IP network.

ProSoft Technology, Inc.

1.2 Release Enhancements

Release	Release Date	Description
Version		
1.001.040	1-Nov-2022	Minimum firmware revision required to run on hardware with the "HB" designation in the F/W REV product label.
1.001.039	21-Jun-2021	 Added support to emulate Legacy Prolinx slave device EtherNet/IP Explicit Messaging feature Added support to allow a DP Master to upload configuration Added byte/word swapping at device level Added support for Modbus FC 5 & 6
1.001.037	31-Mar-2021	Added Non-SINT Array support EtherNet/IP Explicit Messaging feature Fixed PROFIBUS Endian Format in Modbus mode for INT data type
1.001.035	6-Jul-2020	Added support for configuration upload Fixed issues: Data exchange bits to clear after slave node address change Supports Modbus function 5 and 6 Slave sends requests to Modbus register when auxiliary map is enabled
1.001.032	9-Jan-2020	Added Modbus TCP/IP and RTU functionality Added Modbus Auxiliary Map and Modbus Packet Capture to PLX50CU Fixed issues with previous EIP release Show major, minor, and build revisions in Status Window TCP/ARP tab of status window display issue
1.001.017	28-Aug-2019	Release

ProSoft Technology, Inc. Page 5 of 6

2 Support, Service & Warranty

2.1 Contacting Technical Support

ProSoft Technology, Inc. is committed to providing the most efficient and effective support possible. Before calling, please gather the following information to assist in expediting this process:

- 1 Product Version Number
- 2 System architecture
- 3 Network details

If the issue is hardware related, we will also need information regarding:

- 1 Module configuration and associated ladder files, if any
- 2 Module operation and any unusual behavior
- 3 Configuration/Debug status information
- 4 LED patterns
- 5 Details about the interfaced serial, Ethernet or Fieldbus devices

North America (Corporate Location)	Europe / Middle East / Africa Regional Office
Phone: +1 661-716-5100	Phone: +33.(0)5.34.36.87.20
ps.prosofttechnology@belden.com	ps.europe@belden.com
Languages spoken: English, Spanish	Languages spoken: English, French, Hindi, Italian
REGIONAL TECH SUPPORT	REGIONAL TECH SUPPORT
ps.support@belden.com	ps.support.emea@belden.com
Latin America Regional Office	Asia Pacific Regional Office
Phone: +52.222.264.1814	Phone: +60.3.2247.1898
ps.latinam@belden.com	ps.asiapc@belden.com
Languages spoken: English, Spanish,	Languages spoken: Bahasa, Chinese, English,
Portuguese	Hindi, Japanese, Korean, Malay
REGIONAL TECH SUPPORT	REGIONAL TECH SUPPORT
ps.support.la@belden.com	ps.support.ap@belden.com

For additional ProSoft Technology contacts in your area, please see: www.prosoft-technology.com/About-Us/Contact-Us

2.2 Warranty Information

For details regarding ProSoft Technology's legal terms and conditions, please see: www.prosoft-technology.com/ProSoft-Technology-Legal-Terms-and-Conditions

For Return Material Authorization information, please see: www.prosoft-technology.com/Services-Support/Return-Material-Instructions

ProSoft Technology, Inc. Page 6 of 6